

CERTIFICATE OF COMPLIANCE

Certificate Number MH64573
Report Reference MH64573-20200909
Issue Date 2020-SEPTEMBER-09

Issued to: BOND VALVES COMPANY LLC
6659 Schaefer Rd
Dearborn, MI 48126

**This certificate confirms that
representative samples of**

MANUAL VALVES;LP-GAS SHUTOFF VALVES

Shutoff valve, for 1/4, 3/8, 1/2, 3/4, 1 in. sizes, for G, LP at 125°F max 600 psig for NPT type inlet/outlet, Models 300-101(1/4"), 300-102(3/8"), 300-103(1/2"), 300-104(3/4"), 300-105(1").

Shutoff valves, for 1-1/4, 1-1/2, 2 in. sizes, for G, LP at 125°F max 300 psig for NPT type inlet/outlet, Models 300-106(1 1/4"), 300-107(1 1/2"), 300-108(2").

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: See Addendum for Standards.

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number MH64573
Report Reference MH64573-20200909
Issue Date 2020-SEPTEMBER-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

STANDARDS:

UL 125, Valves for Anhydrous Ammonia and LP-Gas (Other Than Safety Relief),
UL 842, Valves for Flammable Fluids
ULC/ORD-C125, Valves For Anhydrous Ammonia And Propane (Other Than Safety Relief),
ULC Subject C842, Valves for Flammable and Combustible Liquids



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

